

A DIVISION OF MAGNATROL VALVE CORP.

941 HAMILTON AVENUE ROEBLING, NJ 08554 WWW.CLARKCOOPER.COM 856 829 4580

Listing Information

Document Issue: 2024.1

| Title: | EXPLOSION-PROOF ENCLOSURES FOR USE IN CLASS I HAZARDOUS LOCATIONS |
|--------------|--|
| Company: | Clark Cooper |
| Product | 10 Series Solenoids, Clark Cooper, Model Nos. 358017; followed by 0, 1, or 2; |
| Information: | followed by 0, 1, 2, 3, 4, 5, 7, 8, or 9; followed by NXX. |
| | All for use in: Class I Div 1 & 2, Groups A, B, C, D; Class II, Div 1 & 2, |
| | Groups E, F, & G |
| | |
| | 10 watt solenoid coils: |
| | Temperature code T4: Ambient temperature range of -20 C to 65.6 C and maximum fluid temperature of 121.1 C |
| | 22 watt solenoid coils: |
| | Temperature code T3C: Ambient temperature range of -20 C to 50 C and maximum fluid temperature of 65.0 C |
| | maximum mulu temperature of 05.0 C |
| Evaluated to | A representative sample of the listed devices have been tested, investigated, and |
| the | found to comply with the requirements of the Standard(s) for Explosion-Proof |
| following: | Enclosures for use in Class 1 Hazardous Locations (UL-1203 & CAN/CSA- |
| | C22.2 No. 30) and are identified with the cETL Listed Mark |

Please refer to the 10 Series Solenoid Coil manual for additional information.

This document contains a reproduction of the listing information in entirety found on the Intertek Directory of Listed Products. To receive this information directly from Intertek, please write to: etlvalidations@intertek.com